



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 6, 2013

BRAUN CONCRETE & EXCAVATING, INC.
TOM REIGEL
609 W SOUTH ST
LOYAL WI 54446

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED (voluntary)
Manufacturer: BRAUN CONCRETE & EXCAVATING, INC.
Product Name: HOLDING TANK
Model Number(s): MARAWOOD 5000
(90" L.L., 53.21 GAL/IN., 36" MAX. BURY DEPTH, 4789 TOTAL GALLONS)
Product File No: 20130197

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval supersedes the approval issued on July 21, 2008 under product file number 20080326.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

A handwritten signature in cursive script that reads 'Sally Shumaker'.

Sally Shumaker
POWTS Plan Reviewer/ Plumbing Product Reviewer
phone: (608) 264-7782
fax: (608) 267-9723
email: sally.shumaker@wisconsin.gov