



August 12, 2013

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: SEPTIC/SEPTIC, HOLDING, SEPTIC/PUMP, OR SEPTIC/SIPHON
Model Number(s): W3000/3000
(48" L.L., 62.43/62.43 GAL/IN., 96" MAX. DEPTH OF BURY, 2780 G.P.D. WHEN USED AS
A
SEPTIC/SEPTIC TANK OR 1390 G.P.D WHEN USED AS A SEPTIC/PUMP OR
SEPTIC/SIPHON TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20130202

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval supersedes the approval issued on September 15, 2008 under product file number 20080491.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Side opening for when product is used as a holding tank.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Four inch discharge opening in riser.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with one access opening above each inlet.
- This tank must be designed to withstand the pressures to which it will be subjected.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

WIESER CONCRETE PRODUCTS, INC.

August 12, 2013

Page 2 of 2

Product File No.: 20130202

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,



Sally A. Shumaker - POWTS Plan Reviewer/Plumbing Product Reviewer

Bureau of Technical Services

Division of Industry Services

Department of Safety and Professional Services

(608) 264-7782 Phone

(608) 267-9723 Fax

saly.shumaker@wisconsin.gov