



August 12, 2013

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: ADVANTEX AX 450 GPD
Model Number(s): WLP 1000/650 FDL
(L.L. 41 IN.; 24.74/15.94 GAL/IN.)
Product File No: 20130204

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval supersedes the approval issued on September 15, 2008 under product file number 20080490.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Side opening for when product is used as a holding tank.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Four inch discharge opening in riser.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with one access opening above each inlet.
- This tank must be designed to withstand the pressures to which it will be subjected.
- This tank may only be installed in conjunction with the Orenco Systems Inc., AdvanTex AX-10 or AX-20 series sewage treatment apparatus.
- The maximum daily wastewater flow which may discharge through this product is 450 gallons per day when the product is installed with a Advantex AX-10 and 600 gallons per day when the product is installed with a Advantex AX-20.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.


WIESER CONCRETE PRODUCTS, INC.

August 12, 2013

Page 2 of 2

Product File No.: 20130204

Sincerely,

A handwritten signature in cursive script that reads "Sally Shumaker".

Sally A. Shumaker - POWTS Plan Reviewer/Plumbing Product Reviewer

Bureau of Technical Services

Division of Industry Services

Department of Safety and Professional Services

(608) 264-7782 Phone

(608) 267-9723 Fax

saly.shumaker@wisconsin.gov