



August 30, 2013

BEAR ONSITE, LLC.
THEO B. TERRY III
55 THOMPSON WAY
PO BOX 507
SOMMERVILLE TN 38068

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: BEAR ONSITE, LLC.
Product Name: MULTI-LEVEL EFFLUENT FILTER
Model Number(s): ML2-920 (ORANGE LID COLOR)
MAX. 3500 GPD; PARTICLE SIZE >1/16 IN. DIA. FILTRATION;
REQUIRE L.L. AT LEAST 20 IN. BELOW THE INVERT OF THE OUTLET; INSTALLED
SINGLY OR IN MULTIPLES.
Product File No: 20130208

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2018.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product must be installed in sewage treatment tanks approved by the Department of Safety & Professional Services, Division of Industry Services for use with this product.
- The discharge rate of the filter must allow sufficient flow to prevent the tank's inlet from becoming submerged.
- All electrical components must meet NEC and in the case of pump/aerators, all must maintain a visual and/or audible alarm in case of failure/need for maintenance.
- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones, M.S.
POWTS Products Review
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov