



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 14, 2013

NORWESCO, INC.
ANASTASIA R. O'HARA

PO BOX 439
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: NORWESCO, INC.
Product Name: SEPTIC
Model Number(s): 1250
(53.5 IN. L.L., 36 IN. MAX. DEPTH OF BURY; 608 G.P.D. WHEN USED AS A SEPTIC
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20130225

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This alternate approval is valid until the end of August 2018.**

This alternate approval supersedes the approval issued on June 25, 2008 under product file number 20080318.


This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The manufacturer's manhole lid and eight inch pipe riser must be installed on one of the manholes to provide an inspection opening.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25 (8) (b), Wis. Admin. Code must be securely attached to the manhole cover.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

NORWESCO, INC.
August 14, 2013
Page 2 of 2
Product File No.: 20130225

Sincerely,

A handwritten signature in cursive script that reads "Sally Shumaker".

Sally A. Shumaker - POWTS Plan Reviewer/Plumbing Product Reviewer
Bureau of Technical Services
Division of Industry Services
Department of Safety and Professional Services
(608) 264-7782 Phone
(608) 267-9723 Fax
saly.shumaker@wisconsin.gov