



September 11, 2013

EVERGREEN CONCRETE PRODUCTS  
RUSIN'S EVERGREEN ENTERPRISES INC.  
ED RUSIN  
1681 N NORTH 2ND DR  
STEVENS POINT WI 54481

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: EVERGREEN CONCRETE PRODUCTS  
Product Name: SEPTIC, HOLDING, PUMP OR GREASE INTERCEPTOR  
Model Number(s): 650 GALLON  
(38.0" L.L., 17.37 GAL/IN. 48" MAX. DEPTH OF BURY, 316 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 78 IN. L X 66 IN. W X 57.5 IN. H)  
Product File No: 20130226

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of September 2018.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones, M.S.  
POWTS Product Review  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov