DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 12, 2013

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: SEPTIC, SIPHON, PUMP OR HOLDING
Model Number(s): W38,000
(125.5" L.L., 305.12 GAL/IN., 96" MAX. DEPTH OF BURY, GPD 17,884 WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20130232

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval supersedes the approval issued on 1/25/2008 under product file number 20080037.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Side opening for when product is used as a holding tank.
  - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Four inch discharge opening in riser.
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Six inch inlet and outlet openings.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
  - Dual inlets at end of tank with one access opening above both inlets.
  - Dual inlets at end of tank with one access opening above each inlet.

- This tank must be designed to withstand the pressures to which it will be subjected.

- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Sally A. Shumaker - POWTS Plan Reviewer/Plumbing Product Reviewer
Bureau of Technical Services
Division of Industry Services
Department of Safety and Professional Services
(608) 264-7782 Phone
(608) 267-9723 Fax
saly.shumaker@wisconsin.gov