



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 21, 2013

JAY R. SMITH MFG. CO
CHRIS LEVINS
2781 GUNTER PARK DR
MONTGOMERY AL 36109

Re: Description: VALVE, BACKWATER
Manufacturer: JAY R. SMITH MFG. CO
Product Name: FLOOD-GATE
Model Number(s): 7140Y04 and 7140Y06
Product File No: 20130251

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval supersedes the approval issued on September 5, 2008 under product file number 20080471.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in an accessible ventilated area.
- Model 7140Y04 must be installed in a horizontal drain line that is at least 9 inches below the fixture outlets to which it is protecting.
- Model 7140Y06 must be installed in a horizontal drain line that is at least 14 inches below the fixture outlets to which it is protecting.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail