



August 26, 2013

THERMO ELECTRON CORPORATION
ANATOMICAL PATHOLOGY/CLINICAL DIAGNOSTIC
RONALD D.GREEN
171 INDUSTRY DR.
PITTSBURGH PA 15275

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: THERMO ELECTRON CORPORATION
Product Name: GROSSLAB SENIOR PATHOLOGY WORK STATIONS
Model Number(s): 9700, 97001, 97002, 97006, 97007, 97008, 970022, 9700122, 9700222, 9700622, 9700722
and 9700822
Product File No: 20130259

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.32 (4) (b) 1. & 2. and 384.30 (5) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval supersedes the approval issued on July 7, 2008 under product file number 20080297.

This alternate approval is contingent upon compliance with the following stipulation(s):

- When this product is installed, the pressure vacuum breaker (Watts 008QT) shall:
 1. be installed in accordance with s. SPS 382.41 (4) (k);
 2. be registered and tested in accordance with s. SPS 382.20 (1)(c) of the Wis. Adm. Code, and
 3. conform to ASSE Standard 1056 and/or CSA Standard B64.1.3.
- The installation of the flexible fixture drain serving this product must be installed in such a manner that the drain will drain by gravity to the fixture trap serving this product when the product is at any height. The drain line for these devices must discharge via an acceptable air gap (ASME A112.1.2).
- The fixture trap serving this product must be located as close as practicable and be at least 3" in size.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail