



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

September 12, 2013

RECTORSEAL
MELISSA SCHOENBERG
2601 SPENWICK DRIVE
HOUSTON TX 77055-1035

Re: Description: FITTINGS, TEST COUPLINGS, DWV
Manufacturer: RECTORSEAL
Product Name: HUBSETT TEST COUPLING
Model Number(s): HUBSETT TEST COUPLING: ABS (HORIZONTAL) 3", 4"; PVC (HORIZONTAL) 3", 4"; ABS (VERTICAL) 3", 4"; PVC (VERTICAL) 3",4"; ABS (PIPE ONLY) 3", 4"; and PVC (PIPE ONLY) 3", 4" AND 4" PVC HUB X SPIGOT (HORIZONTAL)
Product File No: 20130268

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.30 (9) (c) 2. , Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2018.

This approval supersedes the approval issued on December 29, 2008 under product file number 20080369.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail