



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

November 8, 2013

KEMCO SYSTEMS INCORPORATED
JOHN R. O'HENIR
11500 47TH STREET NORTH
CLEARWATER FL 33762

Re: Description: WATER HEATER
Manufacturer: KEMCO SYSTEMS INCORPORATED
Product Name: DIRECT CONTACT WATER HEATERS
Model Number(s): TE100-.75, TE100-1.0, TE100-1.2, TE100-2.0, TE1002.5, TE100-3.0, TE100-3.5,
TE100-4.0, TE100-4.5, TE100-5.0, TE100-5.5, TE100-6.0, TE100-6.5, TE100-7.0,
TE100-8.0, TE100-9.0, TE100-10.0, TE100-12.0, TE100-14.0, TE100-15.0, TE100-16.0,
TE100-18.0, TE100-19.0, TE100-20.0, TE100-21.0, TE100-22.5, TE100-25.0, TE100-27.5,
TE100-30.0, TE100-32.5, TE100-35.0 AND TE100-37.5
Product File No: 20130296

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.40 (5) (d), 384.20 (5) (p) 2. & 3., Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2018.

This alternate approval was required because these water heaters do not rely on the conventional safety devices presently listed in the Wis. Adm. Code to remain operationally safe.

These devices must be installed and maintained in strict accordance with the manufacturer's published instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail