



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

November 11, 2013

CHUDNOW MFG
ROD HEARST
3055 NEW ST BOX 10
OCEANSIDE NY 11572

Re: Description: BACKFLOW PREVENTER FOR CARBONATED BEVERAGE MACHINES - ASSE 1022
Manufacturer: CHUDNOW MFG
Product Name: AUTOMATIC VENTING DEVICE
Model Number(s): S470D-VV**** ASTERISKS DENOTE NUMBERS OR LETTERS OF VARIATIONS WHICH
DO NOT CHANGE THE APPROVED OPERATION OF THE BASE MODEL NUMBER
SHOWN
Product File No: 20130310

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 (3) (a) 1. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2018.

This approval supersedes the approval issued on December 29, 2008 under product file number 20080370.

This alternate approval is required because presently, ASSE Standard 1032 is not a standard recognized under s. SPS 382.41 Wis. Adm. Code

This alternate approval is contingent upon compliance with the following stipulation(s):

- This device may only serve beverage dispensing equipment. When this device serves carbonated dispensing equipment copper pipe and/or tubing may not be used down stream of this device.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail