



October 29, 2013

WIESER CONCRETE PRODUCTS, INC.  
MARK WIESER  
2815 RILEY ROAD  
PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS  
Manufacturer: WIESER CONCRETE PRODUCTS, INC.  
Product Name: 3000 GPD BIO-MICROBICS UNIT MICRO AND HIGH STRENGTH FAST 3.0  
Model Number(s): W4500 BIO  
[MAX. DWF 3000 GPD; TANK DIMENSIONS (OD) = 164 IN. L X 96 IN. W X 98 IN. H]  
Product File No: 20130311

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2018.**

This approval supersedes the approval issued on 10/23/2008 under product file number 20080602.

This approval is contingent upon compliance with the following stipulation(s):

- This tank may only be used when installed with the Bio-Microbics Micro or High Strength Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- 1. A copy of this approval letter must be supplied to the buyer and installer of each tank sold.
  2. All laitance, loose or foreign material must be removed from each joint surface prior to the sealant being applied.
  3. Continuous sealant meeting Federal Specification SS-S-00210-A must be applied to each tongue and groove wall joint.
  4. After placement of the concrete sections on the sealant, continuous squeeze-out of the sealant must be visible inside and outside the tank.
  5. A certified plumbing inspector must confirm compliance with limitations 2, 3 and 4 above, by direct observations during each process.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- The maximum daily wastewater flow which may discharge through this product is 3000 gallons per day.

WIESER CONCRETE PRODUCTS, INC.

Page 2

October 29, 2013

Product File No: 20130311

- This approval shall become null and void if the approval for Bio-Microbics MICRO AND HIGH STRENGTH FAST 3.0 units are not kept current.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov