



November 6, 2013

ZOELLER PUMP CO.
WES COMBS
3649 CANE RUN RD
LOUISVILLE KY 40211

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT
Manufacturer: ZOELLER PUMP CO.
Product Name: EFFLUENT FILTER CONTAINER
Model Number(s): 18 IN. DIA.
(CONTAINER ASSEMBLY w/12" RISER AND LID (#5090-0001),
12" RISER EXTENSION w/HARDWARE AND GASKET (#31-1473),
6" RISER; RISER EXTENSION w/HARDWARE AND GASKET (#31-1476)
Product File No: 20130325

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2018.**

This approval supersedes the approval issued on 1/21/2009 under product file number 20090011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- All manhole covers terminating at or above grade must have effective locking devices.
- This product must have an approved effluent filter installed on the outlet.
- A manhole extending to at least 4 inches above finished grade must be provided over the effluent filter.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov