



November 14, 2013

LAKE SHORE BURIAL VAULT CO., INC.
HUBERT MCQUESTION
12780 LISBON ROAD
BROOKFIELD WI 53005

Re: Description: SEWAGE TREATMENT APPARATUS & TANK SYSTEM [SEE STA -SEWAGE TREATMENT APPARATUS]
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.
Product Name: SEPTIC/ECO POD/PUMP
Model Number(s): 2675 EP [IN CONJUNCTION WITH ECO POD 75/E75CA]
(3 COMPARTMENT: 825/1060/790 GAL, RESPECTIVELY; L.L. 69/67/66 IN.; 12/16/12 GAL. PER INCH PER COMPARTMENT; 96 IN. MAX. DEPTH OF BURY)
[SEE TREATMENT LEVEL FOR APPROVED PRE-TREATMENT UNIT IN APPROVAL LETTER]
Product File No: 20130328

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2018.**

This approval supersedes the approval issued on 4/29/2010 under product file number 20080190.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 750 gallons per day.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25 (8) (b), Wis. Admin. Code must be securely attached to the manhole cover.
- Optional manhole riser with 6 – 24 inch in height.
- This approval remains in effect while the E75 ECO POD media chamber is also in effect.
- Approved levels of treatment for the inserted SEWAGE TREATMENT APPARATUS are found in the approval letter for the specific device(s).

LAKE SHORE BURIAL VAULT CO., INC.

Page 2

November 14, 2013

Product File No: 20130328

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.

POWTS Product Reviewer

phone: (608) 267-5265

fax: (608) 267-9723

email: glen.jones@wi.gov