



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

December 19, 2013

RECTORSEAL
MELISSA SCHOENBERG
2601 SPENWICK DRIVE
HOUSTON TX 77055-1035

Re: Description: VALVE, BACKWATER
Manufacturer: RECTORSEAL
Product Name: CLEAN CHECK EXTENDABLE BACKWATER VALVE
Model Number(s): 96903 (3" ABS), 96923 (3"PVC), 96904 (4" ABS) 96924 (4"PVC), 96926 (6" PVC) 96913 (3" ABS W/ADPT & PLUG), 96914 (4" ABS W/ADPT & PLUG), 96933 (3"PVC W/ADPT & PLUG) 96934 (4" PVC W/ADPT & PLUG)
Product File No: 20130367

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) (c) 3. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2018.

This approval supersedes the approval issued on February 4, 2009 under product file number 2090045.

This alternate approval is required because these products do not conform with ASME A112.14.1, CSA B181.1 or CSA B181.2.. However, an alternate approval is issued for these products because the design of the products meets and/or exceeds the requirements of adopted standards for this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail