



February 28, 2014

ECOLOGICAL TANKS, INC.
GEORGE E. JOHNSON
2247 HWY 151 N
DOWNSVILLE LA 71234

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED
Manufacturer: ECOLOGICAL TANKS, INC.
Product Name: AQUA SAFE
Model Number(s): AS750 and AS750EZ
(MAX. DWF 750 GPD; MAX. BOD 5 1.85 LBS./DAY)
Product File No: 20130396

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of February 2019.**

This approval supersedes the approval issued on 02/18/2009 under product file number 20090026.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 750 gallons per day.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- This product must be installed with the optional 20" diameter Poly Riser terminating at or above finished grade.
- The maximum depth of the treatment tank of this product is 30 inches.
- The manhole (entry) openings for these systems shall be a minimum of 23 inches in the least dimension. The inspection ports for these systems shall be a minimum of three inches in the least dimension.

Inspection ports and manhole openings for systems, located below ground, shall extend to a minimum of the finished grade. Inspection, servicing and maintenance openings for these systems shall terminate with a means that prevents entrance of deleterious materials.

Covers for these systems located at, or above, grade for openings larger than eight inches in the greatest dimension shall be provided with locking devices. These locking devices shall remain locked except for inspection, servicing or maintenance purposes.

- MAINTENANCE: This unit only needs to be serviced as often as the tank is pumped. The filter stack is removable without disturbing the pump or piping.
- This filter may be installed in a series for up to 3200 GPD; for greater DWF, see manufacturer.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov