



March 5, 2014

AL'S CONCRETE PRODUCTS, INC.  
BRUCE WIESER  
800 TOWNHALL ROAD  
LA CRESCENT MN 55947

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: AL'S CONCRETE PRODUCTS, INC.  
Product Name: SEPTIC, HOLDING, PUMP OR SIPHON  
Model Number(s): 1250 LP  
(37.0" L.L., 34.2 GAL/IN. 96" MAX. DEPTH OF BURY, 606 G.P.D. WHEN USED AS A  
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER; TANK DIMENSIONS (OD) = 108 IN. L X 84 IN. W X 58 IN. H)  
Product File No: 20140025

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2019.**

This approval supersedes the approval issued on 3/02/2009 under product file number 20090100.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Bedding: A minimum of 4 in. sand or gravel bedding overlying a firm and uniform base is recommended, unless otherwise specified. Tanks should not bear on large boulders or massive rock edges. Correct compaction of bedding material is critical to ensure there is no differential settling.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov