



March 14, 2014

ADVANCED DRAINAGE SYSTEMS, INC.
SALES
BRENT A. YEAGER
1814 PINEVIEW DR.
VERONA WI 53593

ADVANCED DRAINAGE SYSTEMS
NYLOPLAST
TIM RITCHIE
3130 VERONA AVENUE
BUFORD GA 30518

Re: Description: STORMWATER DRAINAGE, ALTERNATE PLUMBING SYSTEM
Manufacturer: ADVANCED DRAINAGE SYSTEMS
Product Name: NYLOPLAST PVC STORM DRAINAGE SYSTEM
Model Number(s): DRAIN BASINS, ROAD AND HIGHWAY STRUCTURE TYPE INLETS BASINS AND DRAIN BASIN/CURB INLET DRAIN STRUCTURE TYPE INLETS IN 8", 10", 12", 15", 18", 24" and 30" DIAMETERS
Product File No: 20140032

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.35 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2019.

This alternate approval is required because this stormwater drainage system may be installed without cleanouts. This approval supersedes the approval issued on January 29, 2009 under product file number 20090039.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This system must be installed in strict accordance with the manufacturer's printed instructions, this approval and the Wis. Adm. Code. If there is a conflict between the manufacturer's installation instructions and this approval or the Wis. Adm. Code, then this approval and the Wis. Adm. Code shall take precedence.
- Location of flow through openings of Drain Basins, Road and Highway structure type inlets basins and Drain Basin / Curb Inlet Drain structure type inlets basins may be at variable elevations and/or locations around the axis of the basin in accordance with manufacturer's specifications noted on drawings numbered 7001-110-012, 7001-110-013, 7001-110-014 entitled 8" and 15" Minimum Angle Between Adapters, 18" and 24" Minimum Angle Between Adapters and 30" Minimum Angle Between Adapters, respectively.
- All connections to storm sewer piping shall be made with the use of watertight adapters.
- All storm sewer materials shall comply with applicable standards referenced in SPS 384 of the Wisconsin Administrative Code.
- When this system is installed without clean outs as required by s. SPS 382.35, Wisconsin Administrative Code, the system must be cleaned by the use of vacuum or jetting system.

Advanced Drainage Systems Inc. – Nyloplast
March 14, 2014
Page 2 of 2
Product File No.: 20140032

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail