



April 4, 2014

PROCON  
PREMIER CONCRETE, INC  
MIKE DONOHUE  
8431 HIGHWAY 57  
BAILEYS HARBOR WI 54202

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: PROCON  
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP OR HOLDING  
Model Number(s): 1836/894  
(60" L.L., 30.39/14.81 GAL/IN., 84" MAX. DEPTH OF BURY, 873 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK OR 1299 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 156 IN. L X 81 IN. W X 77.5 IN. H)  
Product File No: 20140051

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of April 2019.**

This approval supersedes the approval issued on 2/27/2009 under product file number 20090099.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table SPS 384.30-2 or 384.30-11, Wis. Admin. Code poured into access cover.
  - Four inch inlet in tank cover for holding tanks only.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

- Bedding: Place tanks a min. 4 in. of tampered bedding material of which 100% shall pass through  $\frac{3}{4}$  in. screen. Sand, pea gravel, road gravel or  $\frac{3}{4}$  in. screened stone is acceptable. In wet excavations, use min. 6 in. tampered bedding. Bedding shall be raked to allow  $\frac{1}{2}$  in. center depression. Extend bedding min. 6 in. on all sides of tank bottom.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov