



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

May 1, 2014

BURTON ANDERSON
SCOTT MADSEN
1803 S. 124TH
NEW BERLIN WI 53151

WOODFORD MANUFACTURING COMPANY
JIM ENGARD
2121 WAYNOKA ROAD
COLORADO SPRINGS CO 80915

Re: Description: HYDRANT, FREEZE RESISTANT AUTO DRAINING, VACUUM BREAKER WALL-1019
Manufacturer: WOODFORD MANUFACTURING COMPANY
Product Name: MODEL 67, 22, AND 27 SERIES WITH ASSE 1052 BACKFLOW PREVENTER
Model Number(s): 67, B67, HCB67, HC67, 22, B22, 27C, 27CP, 27CP3, 27P, AND 27PX
Product File No: 20140101

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) (c) 12 and SPS 384.30 (5) (c) 20 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2019.

This approval supersedes the approval issued on April 29, 2009 under product file number 20090163.

This alternate approval is required because:

1. Vacuum breaker wall hydrants, freeze resistant automatic draining type, shall conform to ASSE Standard 1019, type A or B.
2. Dual check backflow preventers in freeze resistant wall hydrants shall conform to ASSE 1053.

Based on the information submitted, these devices do not meet either of these code requirements.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail