



May 8, 2014

SIOUX CHIEF MFG. CO., INC.
PRODUCT GROUP DIRECTOR
DONALD G. KUSMEC
P.O. BOX 397
PECULIAR MO 64078

Re: Description: FITTINGS, COPPER-ALTERNATE SYSTEM
Manufacturer: SIOUX CHIEF MFG. CO., INC.
Product Name: BRAZED SADDLE FLANGE JOINT
Model Number(s): 1/2" X 1/2" X 1/2"; 3/4" X 3/4" X 3/4" AND 1" X 1" X 1"
Product File No: 20140114

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2019.

This approval supersedes the approval issued on February 6, 2009 under product file number 20090055.

This alternate approval is required because these pipe fittings do not conform to the standards adopted in the code for pipe and/or fittings.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in aboveground water supply piping.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail