



June 20, 2014

DTR CONCRETE PRODUCTS, LLC  
DUANE ROFFERS  
W 361 COUNTY RD EE  
DE PERE WI 54115

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: DTR CONCRETE PRODUCTS, LLC  
Product Name: SEPTIC/SEPTIC OR HOLDING  
Model Number(s): 1000 (740/268 TWO-COMPARTMENT; 1226 ACTUAL GALLONS FOR HOLDING TANK)  
[37.0 IN. L.L., 20.0/7.25 GAL/IN., 60 IN. MAX. DEPTH OF BURY, 482 G.P.D. WHEN USED  
AS A SEPTIC/SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER; TANK DIMENSIONS (OD) = 118 IN. L X 68 IN. W X 54 IN. H]  
Product File No: 20140153

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2019.**

This approval supersedes the approval issued on 9/16/2009 under product file number 20090323.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is approved to use the following:
  - Department approved plastic risers and covers installed as required by product approval for the plastic risers and covers with the first riser cast into cover at time of tank production.
  - Conduit hole cast in riser for electrical wiring.
  - Polylok IV High Pressure Pipe Boot Seal by Polylok.
  - Four inch cast iron or schedule 40 ABS or PVC elbow cast in end of cover to create an inlet through the cover when the tank is used as a holding tank.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- TANK BEDDING: Provide 2 to 4 in. stone no larger than 1 ½ in. or a sand base 2-4 in. thick. Bedding should be rake, not tamped, as to confirm with the bottom of the tank when settling.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov