



DIVISION OF INDUSTRY SERVICES  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

July 11, 2014

CONTAINMENT SOLUTIONS INCORPORATED  
FLOWTITE TECHNICAL SPECIALIST  
KEVIN SOEDER  
5150 JEFFERSON CHEMICAL ROAD  
CONROE TX 77301

CONTAINMENT SOLUTIONS  
5150 JEFFERSON CHEMICAL RD  
CONROE TX 77301

Re: Description: SEWAGE TANKS, FIBERGLASS  
Manufacturer: CONTAINMENT SOLUTIONS  
Product Name: HOLDING  
Model Number(s): SWT G-6 (8') 4000 GALS. SINGLE-WALL, FIBERGLASS  
(8 FT. DIAMETER, 4000 GALLONS MAX. CAPACITY, 84 IN. MAX. DEPTH OF BURY)  
Product File No: 20140158

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2019.**

This approval supersedes the approval issued on 5/06/2009 under product file number 20090187.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The manhole cover shall be provided with a locking device that conforms to s. SPS 384.25 (7)(h) of the Wisconsin Administrative Code.
- Access and warning label: Access openings are min. 24 in. diameter and up to 36 in.; available in oval; locking device required when buried less than 6 in. below grade; permanent warning label as per s. SPS 384.25.
- Tank bedding: Use of approved bedding and backfill material is critical; materials must be free of ice and dry; material may be: 1/8 to 3/4 in. clean aggregate or 1/8 to 1/2 in. washed crushed stone or gravel; no more than 5% passing through #8 sieve; else contact manufacturer's technical staff.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov