



July 11, 2014

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: BIOMICROBICS MICROFAST 3.0(2) OR 4.5 & HIGH STRENGTH FAST 3.0(2)
Model Number(s): W6010 BIO-(2) 3.0 OR W6010 BIO-(1) 4.5
[79.5 IN. L.L.; 71.26 GAL./IN.; TANK DIMENSIONS (OD) = 184 IN. L X 102 IN. W X 112 IN.
H; SEE MAX. BOD IN LBS./DAY AND MAINTENANCE INTERVAL FOR MICROFAST AND
HIGH STRENGTH FAST UNITS AS SEPARATE APPROVALS]
Product File No: 20140162

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2019.**

This approval supersedes the approval issued on 9/08/2009 under product file number 20090150.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Side opening for when product is used as a holding tank.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Four inch discharge opening in riser.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with one access opening above each inlet.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- **This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.**

WIESER CONCRETE PRODUCTS, INC.

Page 2

July 11, 2014

Product File No: 20140162

- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- Each tank that is utilized in the installation of this product must pass a water tightness test after installation. The water tightness test must comply with s. SPS 384.25 (2) of the Wis. Adm. Code.
- This system must have an adequately sized septic tank for the design upstream of this unit.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov