



June 27, 2014

NORTHLAND SALES INCORPORATED
STEVE MELONE
17949 WEST LINCOLN AVENUE
NEW BERLIN WI 53146-2126

MORRIS GROUP INTERNATIONAL
JAY R. SMITH MANUFACTURING COMPANY
CHRIS RYLANT
2781 GUNTER PARK DRIVE EAST
MONTGOMERY AL 36109-0237

Re: Description: SIPHONIC ROOF DRAIN
Manufacturer: MORRIS GROUP INTERNATIONAL
Product Name: SIPHONIC ROOF DRAIN AND GUTTER DRAIN
Model Number(s): 1005T, 1005Y, 1605T AND 1605Y
Product File No: 20140177

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.36 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2019.

This approval supersedes the approval issued on March 14, 2007 under product file number 20060523.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The roof drains shall conform to ASME A112.6.9-2005 (R2010).
- The design and installation of the siphonic roof drain shall be in accordance with ASPE technical Standard 45.
- All materials shall conform to ASPE Technical Standard 45.
- Each siphonic roof drain and gutter drain shall be permanently marked at the dome, bodies, and baffle plates with the manufacturer name or trademark. The baffle plate and drain body shall also be marked with the baffle model number, resistance value, K, and words "REPLACE MISSING BAFFLE WITH MODEL _____." The marking shall be clearly visible after installation.
- Maintenance of the roof shall conform to information in the packet from Rattenbury Engineering LLC entitled "Recommended Roof Maintenance Plan, Attachment C, dated January 5, 2006".
- Plans and specification for siphonic roof drain systems shall be approved by this Department via plan review, prior to each specific installation of these systems.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail