



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

July 16, 2014

POLYLOK INC./ZABEL
PETER GAVIN
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: POLYLOK INC./ZABEL
Product Name: A1800 SERIES ZABEL FILTER
Model Number(s): A1800-4X18, A1800-4X18-VT-B35, A1800-4X22-VT-B35, A1800-4X18-VT-B40, A1800-4X22-VT-B40, and A1801-4X22
[MAX. DWF = 800 GPD; > 1/16 IN. FILTRATION; FITS 4 IN. OUTLET TEE]
Product File No: 20140195

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2019.**

This approval supersedes the approval issued on 9/15/2009 under product file number 20090317.

This approval is contingent upon compliance with the following stipulation(s):

- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- The maximum daily wastewater flow, which may discharge through this product, is 800 gallons per day.
- MAINTENANCE: Clean filter at inspection/pumping interval.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov