



September 17, 2014

SFA SANIFLO INC.  
JOSE C. PACHAS  
105 NEWFIELD AVE SUITE B  
EDISON NJ 08837

Re: Description: MACERATING PUMP SYSTEM  
Manufacturer: SFA SANIFLO INC.  
Product Name: SANIFLO  
Model Number(s): SANIPLUS (002), SANITOP (017), SANIPACK (011), SANICUBIC 1 (089), SANICUBIC 2 (029), SANICOMPACT (023), SANISWIFT (021), SANIVITE (008) AND SANICONDENS (040)  
Product File No: 20140258

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.30 (10) (b) 3.a. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2019.

This alternate approval is required because the pump and/or discharge piping is less than 1.25 inches in diameter.

This alternate approval is contingent upon compliance with the following stipulation(s):

- All venting of the connecting fixtures must conform to requirements of s. SPS 382.31 (9) of the Wisconsin Administrative code
- Water closets, that discharge to a SANIFLO macerating sewage pump system, must not discharge more than 1.6 gallons per flush.
- The discharge pipe must connect to a sanitary drain system in accordance with s. SPS 382.30 (10) of the Wisconsin Administrative code.
- The venting system serving the macerating unit must conform to requirements of s. SPS 382.31 (8) of the Wisconsin Administrative code, "VENTS FOR SANITARY SUMPS".
- The capacity of these prefabricated pump and sump systems shall be determined via s. SPS 382.30 (10) (c).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail