



December 9, 2014

ZOELLER PUMP COMPANY  
WES COMBS, REGULATORY SPECIALIST  
3649 CANE RUN RD  
LOUISVILLE KY 40211-1961

Re: Description: SEWAGE TREATMENT APPARATUS  
Manufacturer: ZOELLER PUMP COMPANY  
Product Name: "WW" RESIDENTIAL EFFLUENT FILTER  
Model Number(s): 170-0078  
[MAX. DWF 1000 GPD; >1/16 IN. FILTRATION]  
Product File No: 20140273

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of December 2019.**

This approval supersedes the approval issued on 6/01/2009 under product file number 20090159.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than 1000 gallons per day.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product must be installed in sewage treatment tanks approved by the Department of Safety & Professional Services, Division of Industry Services for use with this product.
- This product will prevent solids with a size greater than 1/16" in size from passing.
- When this product is installed at a distance greater than thirty inches (30") below the top of the access opening, a plastic pipe must be securely attached to the socket on top of the filter. The top of the pipe shall terminate with a tee or ell, which is solvent cemented onto the pipe. The top of the pipe must be at a distance less than thirty inches (30") below the top of the access opening.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S. - POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:  
[www.surveymonkey.com/s/dpsiscustomersatisfaction](http://www.surveymonkey.com/s/dpsiscustomersatisfaction)