



October 10, 2014

PRINSCO, INC.
CHATSWORTH FACILITY
RYAN MARCUS
111 E PINE ST.
CHATSWORTH IL 60921

Re: Description: PIPES AND FITTINGS, POLYETHYLENE
Manufacturer: PRINSCO, INC.
Product Name: PRINSCO GOLDLINE SINGLE WALL PIPE
Model Number(s): PIPE 3, 4, 5, 6, 8, 10, 12, 15
FITTINGS 90 DEGREE ELL: 3, 4; STRAIGHT TEE: 4, 5, 6; COMBO TEE: 3 X 4; BLIND
TEE: 4, 5, 6, 8, 10, 12, 15; REDUCING TEE: 5, 6, 8, 10, 12, 15; WYE: 3, 4, 5, 6, 8; STEP
DOWN REDUCER: 4X3, 6X5X4, 5X4, 6X4, 6X5, 8X4, 8X6, 10X4, 10X8, 10X8X6, 12X10,
12X10X8, 15X12, 15X12X10; PLASTA PLUG: 3, 4, 5, 6; INTERNAL END PLUG: 3, 4, 5, 6,
8; EXTERNAL END CAP PLUG: 8, 10, 12, 15; INTERNAL SNAP COUPLER: 3, 4, 5, 6, 8;
SOIL-TIGHT COUPLER: EXTERNAL SNAP COUPLER: 4, 6, 8, 10, 12, 15; SLEEVE
COUPLER KIT: 12, 15; SILT-TIGHT COUPLER: 12, 15.
Product File No: 20140298

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (2) and (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2019.

This approval supersedes the approval issued on October 19, 2009 under product file number 20090347.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Sanitary sewer gravity flow
 - b. Storm sewer gravity flow
 - c. Stormwater infiltration piping gravity flow perforated
- This product is installed for POWTS effluent piping, the product must have 2 rows, and only 2 rows, of perforations parallel to the axis of the pipe and 120 ± 5 degrees apart. The perforations shall be at the nominal 4 and 8 o'clock positions as the pipe is installed.
- This product must be labeled with the following information:
 - a. Manufacturer's name or trademark
 - b. Date of manufacture
 - c. National standards the pipe conforms to
 - d. Nominal size
 - e. Plant designation
 - f. Production line

Prinsco Incorporated
October 10, 2014
Page 2 of 2
Product File No.: 20140298

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail