



April 29, 2015

GROVE CONCRETE & SUPPLY INC.  
PAUL MILLER JR./ SUSAN SMITH  
18426 DURAND AVE  
PO BOX 363  
UNION GROVE WI 53182

Re: Description: SEWAGE TREATMENT APPARATUS, TANK/CONTAINER ONLY  
Manufacturer: GROVE CONCRETE & SUPPLY INC.  
Product Name: CLEARSTREAM 600 GALLON AEROBIC TREATMENT TANK w/500 GALLON  
PRETREATMENT TANK  
Model Number(s): 600NC2  
[MAX. DWF 600 GPD; MAX. BOD 1.5 LBS.; FOR DETAILED TREATMENT  
PERFORMANCE, SEE PRODUCT APPROVAL FOR CLEARSTREAM 600 N]  
Product File No: 20140316

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of April 2020.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 600 gallons per day.
- This product may not be installed more than 18 inches below final grade.
- A septic tank (pretreatment tank/trash trap) with a volume of at least 50% of the gallon per day rating of this product must be installed upstream of this product.
- Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ -inch screen.
- Also refer to the department's product approval stipulations for the sewage treatment apparatus, which may include: maximum daily wastewater flow, influent strength, maximum BOD5, and maintenance intervals.
- Backfill: Fill must contain no stones or debris larger than 3 inches in diameter. Place backfill in uniform layers no larger than 24 inches.

GROVE CONCRETE & SUPPLY INC.

Page 2

April 29, 2015

Product File No: 20140316

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.

POWTS Product Reviewer

phone: (608) 267-5265

fax: (608) 267-9723

email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

[www.surveymonkey.com/s/dspsiscustomersatisfaction](http://www.surveymonkey.com/s/dspsiscustomersatisfaction)