



July 20, 2015

LAKE SHORE BURIAL VAULT CO., INC.
HUBERT MCQUESTION
12780 LISBON ROAD
BROOKFIELD WI 53005

DELTA ENVIRONMENTAL INC.
PENTAIR PUMP GROUP
MIKE CATANZARO
8263 FLORIDA BLVD.
PO BOX 969
DENHAM SPRINGS LA 70726

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED
Manufacturer: DELTA ENVIRONMENTAL INC.
Product Name: WHITEWATER AEROBIC TREATMENT UNIT
Model Number(s): DF-60-CA
(MAX. DWF 600 GPD; MAX. BOD5 1.50 LBS./DAY; PRIMARY TREATMENT TANK
CAPACITY = 300-600 GALS.)
Product File No: 20140332

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2020.**

This approval supersedes the approval issued on 2/09/2010 under product file number 20100073.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- When this product is installed with the optional POLYLOK effluent filter(s) model PL-122, this product is recognized to not discharge any solid or suspended solid exceeding 1/8 inch in diameter.
- When this product is installed with the "UV The Disinfecter" disinfection device and receives wastewater from dwellings and the flow through the UV disinfection does not exceed 6 gallons per minute, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L, and fecal coliform of less than or equal to 10,000 cfu/100 mL.
- This product may be installed with PolyLok effluent filter model PL-122, and/or the "UV The Disinfecter" disinfection device in accordance with the manufacturer installation instructions.
- This device must display a permanent label or dataplate that displays the manufacturers name and address, and the model number of this device.

LAKE SHORE BURIAL VAULT CO., INC.

Page 2

July 20, 2015

Product File No: 20140332

- This product must be installed in a department-approved tank that meets the design criteria for this product, as specified by the device manufacturer. For concrete tanks see: http://dsps.wi.gov/php/sb-ppalopp/prodcode_result.php/STC/SEWAGE_TANKS,_CONCRETE
- **SERVICING:** The manufacturer may require a service contract.
- **TANK BEDDING:** For fiberglass tanks, use min. 6 inches of sand; for concrete tanks, refer to tank manufacturer's recommendations.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction