



February 19, 2015

ACCESSIBLE SYSTEMS, INC  
ARDEN OLSON  
2940 WEEKS AVE SE  
MINNEAPOLIS MN 55414

Re: Description: SINK, SHAMPOO  
Manufacturer: ACCESSIBLE SYSTEMS, INC  
Product Name: ADJUST-A-SINK  
Model Number(s): K100  
Product File No: 20140363

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.32 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2020.

This approval supersedes the approval issued on February 4, 2010 under product file number 20090409. This alternate approval is contingent upon compliance with the following stipulation(s):

- When using a Marble Products 3000W shampoo bowl - Marble Products 3 in 1 Faucet/Spay/Vacuum Breaker, MP#800, 1014U Fixture. This faucet meets ASME A112.18.1 which includes approved backflow protection device(s).
- When using a Belvedere shampoo bowl - Belvedere 503 Vacuum Breaker  
This Vacuum Breaker meets ASSE 1014.
- The vertical distance between the top of the fixture drain outlet and the horizontal center line of the trap outlet shall not exceed 15 inches.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail