



March 4, 2015

DTR CONCRETE PRODUCTS, LLC
DUANE ROFFERS
W 361 COUNTY RD EE
DE PERE WI 54115

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: DTR CONCRETE PRODUCTS, LLC
Product Name: SEPTIC/SEPTIC/SEPTIC OR HOLDING TANK
Model Number(s): 2050 OR 2550 HOLDING (800/500/750 GAL. THREE COMPARTMENT]
(47.5 IN. L.L., 16.8/10.5/15.8 GAL/IN., 60 IN. MAX. DEPTH OF BURY, 982 G.P.D.
WHEN USED AS A SEPTIC/SEPTIC/SEPTIC TANK, 623 G.P.D. WHEN USED AS
A SEPTIC/SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR
RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 175 IN. L X 72 IN. W X 65 IN. H)
Product File No: 20150013

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.
This approval is valid until the end of March 2020.

This approval supersedes the approval issued on 5/11/2010 under product file number 20090334.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.
- This product is approved to use the following:
 - Department approved plastic risers and covers installed as required by product approval for the plastic risers and covers with the first riser cast into cover at time of tank production.
 - Conduit hole cast in riser for electrical wiring.
 - Polylok IV High Pressure Pipe Boot Seal by Polylok.
 - Four inch cast iron or schedule 40 ABS or PVC elbow cast in end of cover to create an inlet through the cover when the tank is used as a holding tank.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- TANK BEDDING: Tank should be bedded with 2-4 inches of sand or stone no larger than 1.5 in. diameter. Bedding should be raked, not tamped, as to conform with the bottom of the tank when settling.

DTR CONCRETE PRODUCTS, LLC

Page 2

March 4, 2015

Product File No: 20150013

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPTS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction