



May 1, 2015

C&J CONCRETE WALLS, LLC
CURVIN BRUBAKER
W8498 CTH X
THORP WI 54771

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED (voluntary)
Manufacturer: C&J CONCRETE WALLS, LLC
Product Name: HOLDING TANK, SITE-CONSTRUCTED
Model Number(s): 5150
[66 IN. L.L.; 78.0 GAL./IN.; TANK WEIGHT = 43,030 LBS.; 48 IN. MAX. DEPTH OF BURY;
TANK DIMENSIONS = 188 IN. L X 96 IN. W X 66 IN. H.; ANTI-CORROSIVE EPOXY COATED]
Product File No: 20150019

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.
This approval is valid until the end of May 2020.

This approval supersedes the approval issued on 6/08/2010 under product file number 20100242.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ -inch screen.
- This product is approved to use the following:
 - Four inch or six inch inlet openings.
 - Inlet may be located in the side or end of the tank.
 - Optional multiple inlets on any wall at 66 in. from tank base.
 - The liquid level of the tank may vary, but not to exceed 66 inches.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspiscustomersatisfaction