



April 17, 2015

Revised Copy

SANIPUR US LLC
JOE HANNIGAN
912 SPRING MILL AVENUE
CONSHOHOCKEN PA 19428

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: SANIPUR US LLC
Product Name: SANIKILL MONOCHLORAMINE SYSTEM
Model Number(s): SKHP-060, SKLP-060, SKLP-150, SKHP-200, SKHP-350, SKLP-400 AND SKLP-800
Product File No: 20150055

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes. The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2020.

This approval is contingent upon compliance with the following stipulation(s):

- The maximum concentration of monochloramine in the treated water shall not exceed 4 mg/l (as Cl₂).
- These device shall be installed and maintained in strict accordance with the manufacturer's published instructions.
- Only the NSF 60 listed, prepackaged, "Enoxin P10 Plus" (i.e. aqueous sodium hypochlorite solution) and "Zebion 50" (i.e. aqueous ammonium chloride solution) may be used with these devices. The chemical containers shall be labeled as required by NSF Standard 60, section 3.5. The use of either chemical may not exceed the maximum use concentration specified in the NSF Standard 60 listing (i.e. Enoxin P10 Plus = 105 mg/l, Zebion = 167 mg/l).
- The use of the "Kepol" additive is not covered under the scope of this approval.
- If used as a primary means of disinfection, the residual levels of monochloramine shall conform to s. NR 810.58 (CT table for viruses when using chloramines) Wis. Adm. Code for 4-log virus reduction.
- If these devices are installed in a healthcare facility, then site specific plan review is required for each installation.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail