



April 23, 2015

JENSEN BRIDGE & SUPPLY CO.
CHRISTOPHER LODING
400 STONEY CREEK DRIVE
PO BOX 151
SANDUSKY MI 48471

Re: Description: PIPES AND FITTINGS, ALUMINIZED STEEL (SEE ALSO STORMWATER DETENTION SYSTEMS)
Manufacturer: JENSEN BRIDGE & SUPPLY CO.
Product Name: CORRUGATED METAL PIPE UNDERGROUND DETENTION SYSTEM
Model Number(s): CORRUGATED PIPE
Product File No: 20150060

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 & 384.40 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2020.

This approval supersedes the approval issued on May 14, 2010 under product file number 20100185.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must conform to American Association of State Highway and Transportation Officials (AASHTO) standard M36/M 36M-90.
- This product may be installed for the following drain and vent use(s):
 - a. Storm sewer gravity flow
- This review does not include approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product is approved for the following uses:
 - Stormwater and clearwater subsurface detention system.
- When this product is installed as a subsurface detention system, the installation must be in accordance with the manufacturer's printed instructions. When there is a conflict between the manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.

Sizing of piping for stormwater and clearwater subsurface detention shall be made using hydraulic calculations as specified in manufacturer's instructions.

- CSP field joints shall be made with a 5-C band with 3^{1/2}" X 8" bolts and a 12" wide X 1/4" thick BIDCO gasket.

Jensen Bridge & Supply Company
April 23, 2015
Page 2 of 2
Product File No.: 20150060

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail