



**Scott Walker, Governor**  
**Dave Ross, Secretary**

May 07, 2015

CUST ID No. 1315288

DAVID URBAN  
MCC INC  
N7820 OLD HWY 141  
CRIVITZ WI 54114

Identification Numbers
<b>Transaction ID No. 2528679</b>
<b>Site ID No.</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

Re: Description: SEWAGE TANKS, CONCRETE  
 Manufacturer: MCC INCORPORATED  
 Product Name: SEPTIC, HOLDING OR PUMP (trans id 2528679)  
 Model Number(s): 1,000 GAL.  
 (43.0 IN. L.L., 23.74 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 489 G.P.D. WHEN USED  
 AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 97 IN. L X 68 IN. W X 59 IN. H)  
 Product File No: 20150087

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2020.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - 3/4" diameter opening in the access riser.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

- **BEDDING AND BACKFILL:** Tank bedding must be 3 in. of compacted sand, gravel or lime rock of which 100% will pass through ½-inch screen. Backfill material must be material that 100% will pass through a 4-inch screen and tamped into place.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov

The DSPTS is committed to service excellence. Visit our survey at:

[www.surveymonkey.com/s/dspsiscustomersatisfaction](http://www.surveymonkey.com/s/dspsiscustomersatisfaction)