



May 26, 2015

CUST ID No. 1316954

BRUCE WIESER
ALS CONCRETE PRODUCTS INC
800 TOWNHALL ROAD
LA CRESCENT MN 55947

Identification Numbers
Transaction ID No. 2534219
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: AL'S CONCRETE PRODUCTS, INC.
Product Name: SEPTIC, HOLDING, PUMP & SIPHON (trans. id 2534219)
Model Number(s): 750 LP
(37.0 IN. L.L., 21.1 GAL/IN., 96 IN. MAX. DEPTH OF BURY, 373 G.P.D. WHEN USED
AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 84 IN. L X 72 IN. W X 58 IN. H; ACTUAL CAPACITY IN GALS.: 777 SEPTIC, 820 HOLDING, PUMP AND SIPHON; * FLOAT SIPHON 8 IN. DRAWDOWN= 168 GAL./DOSE; FLUID DYNAMICS SIPHON 7 IN. DRAWDOWN, 147 GAL./DOSE)
Product File No: 20150110

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2020.**

This approval supersedes the approval issued on 10/30/2009 under product file number 20090359.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Four inch discharge opening in riser.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with one access opening above each inlet.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Department approved plastic risers and covers installed as required by product approval for the plastic risers and covers with the first riser cast into cover at time of tank production.
- Bedding: A minimum of 4 in. sand or gravel bedding overlying a firm and uniform base is recommended, unless otherwise specified. Tanks should not bear on large boulders or massive rock edges. Correct compaction of bedding material is critical to ensure there is no differential settling.
- Backfill: Sidewall backfill must consist of material 100% of which will pass through a 2-in. screen and be made up of dry soil, sand or gravel. A minimum (average) of 12 inches on all sides of the tank from the base to the top is recommended. No parallel backfilling or compaction along the sidewalls is recommended. No wheel tracking or track loading on the sidewall is recommended. Cover-backfill up top 7-feet of loading must be dry and pass through a 4-inch screen.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPTS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction