



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

June 11, 2015

WILLOUGHBY INDUSTRIES INC.
ASHLIN HASKETT
5105 W 78TH ST.
INDIANAPOLIS IN 46268

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: WILLOUGHBY INDUSTRIES INC.
Product Name: PATIENT CARE UNIT (trans id 2553985)
Model Number(s): WH-1700, WH-1750, WH-1900, WH-1950, WH-2100, WH-2400 AND WH-2800
Product File No: 20150152

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2020.

This approval is contingent upon compliance with the following stipulation(s):

- The influent water pressure to these units shall be ≥ 35 psig.
- All units shall be properly trapped in accordance with s. SPS 382.32 Wis. Adm. Code.
- Back to back installations of these units shall conform to s. SPS 382.30 (8) (b.) Wis. Adm. Code.
- A spill resistant vacuum breaker (VB) that conforms to ASSE 1056 or CAN/CSA B64.1.3 shall be installed in the fixture supply serving the bed pan washer/dialysis box. In addition, the VB shall:
 1. be installed in accordance with s. SPS 382.41 (4) (n) Wis. Adm. Code;
 2. be tested in accordance with s. SPS 382.22 (8) Wis. Adm. Code; and
 3. be registered with this department in accordance with s. SPS 382.20 (1) (c) Wis. Adm. Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail