



January 27, 2016

T&S BRASS
ENVIROPURE SYSTEMS
JIM SLANINA
50 SADDLEBACK COVE
TRAVELERS REST SC 29690

Re: Description: NON-SEWER FOOD WASTE HANDLING SYSTEM
Manufacturer: T&S BRASS
Product Name: ENVIROPURE ORGANIC WASTE DIGESTER - EPW SERIES (trans id 2567774)
Model Number(s): EPW-XXXX
Product File No: 20150179

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 (5) (h), 384.20 (5) (m) 1. c. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2021.

This alternate approval is contingent upon compliance with the following stipulation(s):

- These devices shall be installed by a properly licensed Wisconsin plumber.
- These devices shall be properly vented in accordance with s. SPS 382.31 Wis. Adm. Code. The venting pipe material shall conform to s. SPS 384.30 (2) (a) Wis. Adm. Code.
- All water supply piping serving these devices shall conform, to s. SPS 384.30 (4) (d) Wis. Adm. Code.
- The water supply piping to these devices shall be $\geq \frac{3}{4}$ -inches in diameter up to the point where the piping is split between the hand-held spray and the food waste grinder.
- A reduce pressure zone (RPZ) cross connection control device that conforms to ASSE 1013 shall be installed in hot and cold water lines serving these devices. The RPZ shall be installed in accordance with s. SPS 382.41 (5) (f) Wis. Adm. Code. The RPZ shall be registered and tested as specified in s. SPS 382.22 (8) Wis. Adm. Code.
- No peripheral items (e.g. faucets sprays, feeders, etc.) may be added to these devices as provided by Enviropure Systems.
- If the wastes from these systems is disposed of via a private onsite waste treatment system (POWTS), then the POWTS shall be in full compliance with ch. SPS 383 Wis. Adm. Code.
- If the wastes from these systems is disposed of via a commercial/municipal anaerobic digester, then the digester shall be in full compliance with ch. NR 110 Wis. Adm. Code.
- These devices shall bear a conspicuous label indicating the water is unfit for human consumption. The label shall be clearly visible after installation is complete.
- These devices shall not be installed in areas subject to freezing.

T&S Brass – Enviropure Systems
January 27, 2016
Page 2 of 2
Product File No.: 20150179

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail