



August 31, 2015

STERISIL INCORPORATED
PETER VERHEY
835 S HIGHWAY 105, SUITE D
PALMER LAKE CO 80133

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: STERISIL INCORPORATED
Product Name: STERASIL SYSTEM (trans id 2574709)
Model Number(s): AC, AC PLUS, SS-B AND SS-D
Product File No: 20150183

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2020.

This approval is contingent upon compliance with the following stipulation(s):

- These devices are approved for the reduction of naturally occurring heterotrophic plate count (HPC) bacteria only. These devices are not approved for the reduction of pathogenic microorganisms.
- These devices shall be installed on potable water supplies only. Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after these systems.
- The drain lines from these devices shall terminate in air gaps that conform to American Society of Mechanical Engineers (ASME) Standard A112.1.2.
- These devices shall be installed by a properly licensed Wisconsin plumber.
- These devices shall be maintained in accordance with the manufacturer's published instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail