



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 11, 2015

BASE PRODUCTS CORPORATION
WILLIAM BONIFACIO
265 MAYVILLE AVE.
BUFFALO NY 14217

Re: Description: ALTERNATE PRODUCT REVIEW
Manufacturer: BASE PRODUCTS CORPORATION
Product Name: WATER POWERED SUMP PUMP (trans. id 2581875)
Model Number(s): RB750, HB1000 AND CB1500
Product File No: 20150195

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2020.

This approval supersedes the approval issued on December 10, 2010 under product file number 20100389.


This alternate approval is contingent upon compliance with the following stipulation(s):

- This product shall be modified so that the vacuum breaker is 6" above the point of discharge. In order to be in compliance with the ASSE 1001 standard the venturi fitting shall be 6" below the vacuum breaker.

A sketch depicting this modification is Attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,



Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail

ATTACHMENT A

