



Scott Walker, Governor
Dave Ross, Secretary

August 20, 2015

Identification Numbers
Transaction ID No. 2583862
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1320179

MARK WIESER
WIESER CONCRETE PRODUCTS INC
2815 RILEY ROAD
PORTAGE WI 53901

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 08/31/2020

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: FILTER CANISTER (trans id 2583862)
Model Number(s): NONE **[24 IN. DIAMETER CYLINDER; 37.0 IN. L.L.]**
[FOR USE WITH ZABEL FILTER MODELS: A100, A300 or A1800]
Product File No: 20150210

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2020.**

This approval supersedes the approval issued on 8/13/2010 under product file number 20100353.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When Zabel filter model A100, A300 or A1800 is installed in this tank, installation must be in accordance with the filter manufacturer's printed instructions and the filter's product approval stipulations. If there is a conflict between the filter manufacturer's printed instructions and the filter's product approval stipulations, the product approval stipulations will take precedence.
- **BEDDING:** Bedding must be capable of bearing the weight of the tank. Bedding material must have the ability for 100% to pass through 3/4 inch screen. Bedding thickness must be 4 inches minimum compacted (thickness may vary due to soil conditions).

- **BACKFILL:** Sidewalls of tanks must have dry backfill materials that have the ability to pass 100% through a 2-inch screen. Provide a min. 12 inches on all sides from bottom to top, placed with a backhoe or concrete bucket to avoid impact loads on sidewall of tank. No compaction of backfill material is permitted on sidewalls; if more than 85% modified Proctor compaction is required, then use 3/8- or 3/4-inch washed gravel for backfill material.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction