



September 29, 2015

JAY R. SMITH MFG. CO
CHRIS LEVINS
2781 GUNTER PARK DR
MONTGOMERY AL 36109

Re: Description: BARRIER TYPE FLOOR DRAIN TRAP SEAL PROTECTION DEVICE
Manufacturer: JAY R. SMITH MFG. CO
Product Name: QUAD CLOSE STINK STOPPER TRAP SEAL DEVICE (trans id 2592012)
Model Number(s): 2962-02, 2692-03, 2692-0350 AND 2692-04
Product File No: 20150225

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2020.

This approval is contingent upon compliance with the following stipulation(s):

- These devices are not trap seal primers and shall not be used as such.
- These devices are not backwater valves and shall not be used as such.
- These devices shall maintain conformance to ASSE 1072.
- These devices shall be installed in accordance with the manufacturer's published instructions.
- These devices shall not be installed in areas subjected to less than atmospheric pressure.
- Each device shall be marked with the following:
 1. manufacturer's name or trademark; and
 2. UPC certification mark.

Packaging shall be marked with the following:

- a. manufacturer's name or trademark;
- b. model number or description of device;
- c. rating for type of floor;
- d. rating for grease laden wastes (if applicable); and
- e. floor drain size.

RATED FLOWS

Model Number	Minimum Required Flow Rate (gpm)¹
2692-02	12.0
2692-03	34.0
2692-0350	51.0
2692-04	73.0

1 = ASSE Standard 1072, section I

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail