



**Scott Walker, Governor**  
**Dave Ross, Secretary**

October 07, 2015

Identification Numbers
<b>Transaction ID No. 2611254</b>
<b>Site ID No.</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1064527

MARK WIEDMEYER  
TERRACE HOMES  
1553 11TH DR  
FRIENDSHIP WI 53934

**CONDITIONAL APPROVAL**  
**PLAN APPROVAL EXPIRES: 10/31/2020**

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: TERRACE HOMES  
Product Name: TYPICAL PLUMBING TREE (trans id 2611254)  
Model Number(s): THGS 33  
Product File No: 20150235

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2020.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 45 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on Type M copper tubing must not exceed 112.0 wsfu for 1-1/2-inch tubing, 62.0 wsfu for 1-1/2-inch tubing, 34.0 wsfu for 1-inch tubing, 18.0 wsfu for 3/4-inch tubing and 7.5 wsfu for 1/2-inch tubing.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb  
Plumbing Plan Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
Madison WI 53703-2658  
608-266-9647 Phone  
608-267-9723 Fax  
tim.lamb@wi.gov E-mail  
Sincerely,

Fee Required \$	125.00
Fee Received \$	125.00
Balance Due \$	0.00

WiSMART code: 7657