



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

October 28, 2015

SEALED AIR CORPORATION
DIVERSEY CARE
CURTIS HUBMANN/ ANNA PORTER
1410 N. NEWMAN ROAD
MT. PLEASANT WI 53406

Re: Description: PROPORTIONER
Manufacturer: SEALED AIR CORPORATION
Product Name: J-FILL DISPENSING UNIT (trans id 2623667)
Model Number(s): NONE
Product File No: 20150258

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 (5) (d) Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2020.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed using the water hook-up assembly provided by the manufacturer.
- This product may not be used/installed with the bottom of air gap assembly submerged below the flood level rim of the receptor.
- This product does not require additional, external cross connection control because the device incorporates an acceptable integral air gap.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail