



Scott Walker, Governor
Dave Ross, Secretary

November 24, 2015

Identification Numbers
Transaction ID No. 2625317
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1333306

TOM NEMETZ
IRON CITY ENTERPRISES INC
N2404 HWY 41
MENOMINEE MI 49858

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 11/30/2020

Re: Description: SEWAGE TANKS, CONCRETE
 Manufacturer: IRON CITY ENTERPRISES, INC.
 Product Name: SEPTIC, HOLDING OR PUMP (trans id 2625317)
 Model Number(s): 2000
 (48.0 IN. L.L., 45.8 GAL/IN., 48 IN. MAX. DEPTH OF BURY WITH 6 IN. LID AND 72 IN. MAX DEPTH OF BURY WITH 8 IN. LID, 1053 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; ACTUAL CAPACITY = 2199 GALS.; TANK DIMENSIONS (OD) = 155 IN. L X 78 IN. W X 65 IN. H)
 Product File No: 20150261

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2020.**

This approval supersedes the approval issued on 10/22/2010 under product file number 20100422.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
- Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction