



November 25, 2015

MEDISAFE AMERICA LLC
OLIVIA BLEVINS
9423 CORPORATE LAKE DRIVE
TAMPA FL 33634

MEDISAFE UK LTD.
CHRIS ANDERSON
TWYFORD ROAD
BISHOP STORTFORD, HERTFORDSHIRE UK
CM23 3LJ
UNITED KINGDOM

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: MEDISAFE UK LTD.
Product Name: SONIC IRRIGATOR (trans id xxxxxxxx)
Model Number(s): MED11160USA
Product File No: 20150264

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2020.

This approval is contingent upon compliance with the following stipulation(s):

- The potable water piping serving these devices (i.e. hot, cold and high purity) shall be isolated from the building's water supply system by installing a reduced pressure principle backflow preventer (i.e. RPZ) or spill resistant vacuum breaker (i.e. SRVB). The RPZ shall conform to ASSE Standard 1013. The spill resistant vacuum breaker shall conform to ASSE Standard 1056.
- The RPZ's/SRVB's shall be installed in accordance with s. SPS 382.41 (5) Wis. Adm. Code.
- The RPZ's/SRVB's shall be registered, maintained and repaired in accordance with s. SPS 382.22 Wis. Adm. Code.
- The wastewater from these devices shall be conveyed to the drain, waste and vent (i.e. DWV) system via an air gap. The air gap shall conform to ASME A112.1.2.
- The DWV piping down stream of these devices shall be properly sized to handle the additional wastewater flow and of a material suitable for the maximum wastewater temperature generated by these devices.
- The stainless steel overbraid fixture supply connector hoses supplied with this product shall:
 1. Shall be designed and constructed to withstand a minimum of 100 psig at 180° F; and
 2. The wetted internal surface shall be acceptable for contact with potable water.

Medisafe UK Ltd.
Product File No. 20150264
Page 2 of 2
November 25, 2015

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Dept of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail