



Scott Walker, Governor
Dave Ross, Secretary

November 25, 2015

Identification Numbers
Transaction ID No. 2637302
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1335825

MICHAEL MASON
DESIGN HOMES INC
600 N MARQUETTE RD PO BOX 239
PRAIRIE DU CHIEN WI 53821

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 11/30/2020

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: DESIGN HOMES, INC.
Product Name: TYPICAL KITCHEN SINK PLB DETAIL (trans id 2637302)
Model Number(s): P-7
Product File No: 20150276

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2020.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 12 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.

This approval supersedes the approval issued on November 10, 2010 under product file number 201000465.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-267-9723 Fax
tim.lamb@wi.gov E-mail

Fee Required \$ 125.00

This Amount Will Be Invoiced.
When You Receive That Invoice,
Please Include a Copy With Your
Payment Submittal.

WiSMART code: 7657

Note: Effective January 1, 2012, all codes under the jurisdiction of the Division of Industry Services (formerly Safety & Buildings) will be modified. Code references with prefixes starting with "Comm" have been replaced with "SPS" to recognize the relocation of the Division of Industry Services from the former Department of Commerce to the Department of Safety & Professional Services. Additionally, all IS (formerly S&B) codes have been renumbered and addressed in a "300" series. For future reference, the Wisconsin Commercial Building Code will be addressed by SPS Chapters 360-366.